



## TEST REPORT

PBRP1137e  
Rev.2  
Page 1 of 30

### MODULAR MANIFOLDS FOR HEATING AND COOLING SYSTEMS: VALIDATION TESTS



Issued by:

Dept. Quality Control

Name: LEGE Ermano

Date: 24.06.2014

Signature:

Approvato da:

Dept. Quality Assurance

Name: ZANINI Manuela

Date: 24.06.2014

Signature:



# TEST REPORT

PBRP1137e  
Rev.2  
Page 2 of 30

## **INDEX**

1. Subject .....	page 3
2. Product description .....	page 4
3. Raw materials .....	page 9
4. Performed tests .....	page 10
4.1 Burst pressure at room temperature .....	page 11
4.2 Tightness with low and high pressure .....	page 14
4.3 Life with pulsating pressure and temperature .....	page 15
4.4 Life of the thermostatic valve.....	page 17
4.5 Pressure drop of the manifold .....	page 18
4.6 Pressure drop of the single port of the manifold .....	page 20
4.7 Flow rate with different ports .....	page 26
4.8 Connecting force of the sliding quick connectors .....	page 28
5. Conclusion .....	page 30



## TEST REPORT

PBRP1137e  
Rev.2  
Page 3 of 30

### 1. SUBJECT

This test report describes the technical features, the raw materials used and the tests performed on the manifolds designed by Pres Block for the distribution of water in the underfloor, wall and ceiling heating / cooling systems.


The technical standard for this product is the standard **EN 1264-4**, which does not require specific tests for the validation of the product described in this document.

As a consequence Pres Block has defined internally the tests to be performed, in order to verify the conformity to the technical features requested by the filed of application.

## 2. PRODUCT DESCRIPTION


The products described in this test report are the following:

**Complete manifold with  
supply manifold with flow regulators and  
return manifold for thermo actuators**



PBRP1137e  
Rev.2  
Page 5 of 30

### Supply manifold with flow regulators RCTMD-M







# TEST REPORT

PBRP1137e  
Rev.2  
Page 6 of 30

## Details of supply manifold with flow regulators RCTMD-M



### Return manifold for thermo actuators RCTTV-M









## TEST REPORT

PBRP1137e  
Rev.2  
Page 9 of 30

### 3. RAW MATERIALS

The manifolds described in this test report are made of the following raw materials:

- **PA12, 30% glass reinforced;**
- **PA12;**
- **PA6,6, 30% glass reinforced;**
- **PPO, 30% glass reinforced;**
- **POM;**
- **Grivory;**
- **brass EN 12164 – CW614N;**
- **stainless steel;**
- **peroxidic EPDM.**



## TEST REPORT

PBRP1137e  
Rev.2  
Page 10 of 30

### 4. PERFORMED TESTS

The following tests have been performed:

- burst pressure at room temperature;
- tightness with low and high pressure;
- life with pulsating pressure and temperature;
- life of the thermostatic valve;
- pressure drop of the manifold;
- pressure drop of one single port of the manifold;
- connecting force of the sliding quick connectors.

Tested samples, testing modalities and obtained results are described in the following pages.



## TEST REPORT

PBRP1137e  
Rev.2  
Page 11 of 30

### 4.1 BURST PRESSURE AT ROOM TEMPERATURE

#### Tested samples:


The following samples have been tested:

- n° 3 samples for every type of manifold;
- n° 3 samples for every type of sliding quick connector.

#### Testing modalities:

The samples have been connected with a test bench to a **oil** source, whose pressure has been increased up to the burst.

Picture n° 1  
**Manifolds burst pressure**  
**- Testing modalities -**






## TEST REPORT

PBRP1137e  
Rev.2  
Page 12 of 30

Picture n° 2  
**Quick connectors burst pressure**  
**- Testing modalities -**





## TEST REPORT

PBRP1137e  
Rev.2  
Page 13 of 30

### Obtained results

The obtained results are synthesized in the following table:

Tested sample	Diameter [mm]	Minimum burst pressure
Manifold for thermo actuators RCTTV-M	40	> 24 bar
Manifold with flow regulators RCTMD-M	40	> 24 bar
Button operated connector RPLPUTERRB17	17	50 bar
Button operated connector RPLPUTERRB20	20	40 bar

All the manifolds burst with a pressure higher than 24 bar, due to the breakage of the modular connection between the different ports.

All the sliding quick connectors break on the bayonet connection, with a pressure of 40 bar or higher.



## TEST REPORT

PBRP1137e  
Rev.2  
Page 14 of 30

### 4.2 TIGHTNESS WITH LOW AND HIGH PRESSURE

#### Tested samples:

3 samples for every type of manifold have been tested.

#### Testing modalities:

The samples have been connected to a **hydraulic circuit**, whose pressure has been increased from 0,2 up to 10 bar.

During the test the absence of water leakages has been visually verified.

Picture n° 3

#### Tightness with high pressure - Testing modalities -



#### Obtained results

For pressure of water from 0,2 up to 10 bar, the tightness is always granted.





## TEST REPORT

PBRP1137e  
Rev.2  
Page 15 of 30

### 4.3 LIFE WITH PULSATING PRESSURE AND TEMPERATURE

#### Tested samples:

3 manifolds with flow regulators RCTMD-M have been tested.

#### Testing modalities:

The samples have been connected to a **hydraulic circuit**, whose pressure has been regulated according to the following cycle:

- 2 seconds with water at 6 bar;
- 1 second with water at 0 bar

for totally 1.000.000 cycles.

Also the temperature has been regulated during this test as follows:

- 12 hours at 90 °C;
- 12 hours at -2 °C.

Picture n° 4

#### Life with pulsating pressure and temperature: Steamer - Testing modalities -



Picture n° 5

**Life with pulsating pressure and temperature: Fridge**  
**- Testing modalities -**



**Obtained results**

At the end of the test all the manifolds still grant the tightness and the technical performances.



## 4.4 LIFE OF THE THERMOSTATIC VALVE

### Tested samples:

3 thermostatic valves assembled on one manifold type ICTTV have been tested (different type of manifold, with the same thermostatic valve).

### Testing modalities:

The samples have been tested with a temporized pneumatic cylinder, which simulated the movement of the thermostatic valve, according to the following cycle:

- 2 seconds with the thermostatic valves positioned at end of stroke;
- 2 seconds with the thermostatic valves free;

for totally 1.000.000 cycles.

Inside the manifold **water at 4 bar** was present.

Picture n° 6

**Life of the thermostatic valve**  
**- Tested sample -**



### Obtained results

At the end of the test the O-rings still grant their function.



## TEST REPORT

PBRP1137e  
Rev.2  
Page 18 of 30

### 4.5 PRESSURE DROP OF THE MANIFOLD

#### Tested samples:

A circuit with the following components has been tested:

- 1 supply manifold with 14 flow regulators RCTMD-M
- 1 return manifold for thermo actuators RTEV-M;
- button operated sliding connectors type RPLPUTERRB20/M.


#### Testing modalities:

The circuit has been connected to a **hydraulic circuit**, made with a **LOWARA E A 20 6/130 pump and 20x2 multilayer hoses**. All the valves for the regulation of the flow were closed.

The pressure drop of the circuit has been measured, with 2 pressure gauges positioned upstream and downstream the supply manifolds with flow regulators.

In this same conditions also the flow rate has been measured

Picture n° 7  
**Pressure loss of the manifold**  
**- Tested sample -**



## **Obtained results**

The pressure drop between the first and the final port of the manifold is lower than 0,1 bar.

The flow rate of the manifold, with all the n° 14 exits closed, is 2.460 l/h.



## TEST REPORT

PBRP1137e  
Rev.2  
Page 20 of 30

### 4.6 PRESSURE DROP OF THE SINGLE PORT OF THE MANIFOLD

#### Tested samples:

Following pieces have been tested:

- 1 supply manifold port with flow regulators RCTMD-M;
- 1 return manifold port for thermo actuators RTEV-M.

#### Testing modalities:

The pieces have been tested with a specific test bench.



## TEST REPORT

PBRP1137e  
Rev.2  
Page 21 of 30

Picture n° 8

**Pressure loss of the single port of the manifold**  
**- Giussani Test Bench -**





## TEST REPORT

PBRP1137e  
Rev.2  
Page 22 of 30

### Obtained results

The results are synthesized in the following graphics and tables.

### SUPPLY MANIFOLD WITH FLOW REGULATORS RCTMD-M Pressure Drop





## TEST REPORT

PBRP1137e  
Rev.2  
Page 23 of 30

Pitch	Pressure difference (bar)			Flow rate COMPONENT		Speed Water COMPONENT (m/s)
	■ READ	■ TEST RIG	■ COMPONENT	(l/min)	(kg/min)	
1	0,052	0,000	0,052	1,15	1,14	0,24
2	0,106	0,004	0,102	9,85	9,83	2,09
3	0,156	0,006	0,150	13,68	13,65	2,90
4	0,208	0,008	0,200	16,12	16,09	3,42
5	0,262	0,010	0,251	18,04	18,00	3,82
6	0,311	0,010	0,300	19,98	19,94	4,24
7	0,364	0,013	0,350	21,67	21,62	4,59
8	0,413	0,012	0,400	23,04	22,98	4,88
9	0,465	0,011	0,453	24,24	24,18	5,14
10	0,514	0,014	0,500	25,64	25,58	5,44
11	0,571	0,020	0,551	27,11	27,05	5,75
12	0,620	0,019	0,601	28,36	28,29	6,01
13	0,669	0,017	0,652	29,29	29,22	6,21
14	0,728	0,027	0,701	30,80	30,72	6,53
15	0,781	0,029	0,752	31,82	31,75	6,75
16	0,832	0,031	0,801	32,71	32,64	6,94
17	0,892	0,039	0,852	33,55	33,47	7,11
18	0,939	0,038	0,901	33,99	33,91	7,21
19	0,986	0,035	0,951	34,04	33,97	7,22
20	1,035	0,035	1,000	34,08	34,01	7,23
21	1,085	0,034	1,051	34,13	34,05	7,24

Consequently Kv value, with flow regulator completely open, is 2,04.






## TEST REPORT

PBRP1137e  
Rev.2  
Page 24 of 30

### RETURN MANIFOLD FOR THERMO ACTUATORS RTEV-M Pressure Drop







## TEST REPORT

PBRP1137e  
Rev.2  
Page 25 of 30

Pitch	Pressure difference (bar)			Flow rate COMPONENT		Speed Water COMPONENT (m/s)
	■ READ	■ TEST RIG	■ COMPONENT	(l/min)	(kg/min)	
1	0,059	0,005	0,053	11,04	11,02	0,81
2	0,107	0,007	0,100	15,53	15,51	1,14
3	0,162	0,011	0,150	18,62	18,59	1,37
4	0,215	0,015	0,200	21,74	21,71	1,60
5	0,267	0,015	0,252	24,45	24,41	1,79
6	0,322	0,020	0,302	27,15	27,10	1,99
7	0,368	0,017	0,351	29,01	28,96	2,13
8	0,427	0,025	0,401	31,06	31,01	2,28
9	0,480	0,028	0,452	33,01	32,96	2,42
10	0,534	0,034	0,501	34,87	34,82	2,56
11	0,587	0,036	0,551	36,24	36,18	2,66
12	0,636	0,036	0,600	38,03	37,97	2,79
13	0,685	0,033	0,652	38,73	38,67	2,84
14	0,744	0,042	0,701	41,08	41,02	3,01
15	0,798	0,048	0,750	41,80	41,73	3,07
16	0,849	0,045	0,803	43,33	43,26	3,18
17	0,893	0,041	0,852	44,28	44,21	3,25
18	0,967	0,067	0,901	45,96	45,89	3,37
19	1,015	0,064	0,951	47,00	46,92	3,45
20	1,065	0,064	1,001	47,00	46,92	3,45
21	1,114	0,064	1,050	47,00	46,92	3,45
22	0,000	0,000	0,000	0,00	0,00	0,00

Consequently Kv value is 2,80.



## TEST REPORT

PBRP1137e  
Rev.2  
Page 26 of 30

### FLOW RATE WITH DIFFERENT PORTS

#### Tested samples:

A circuit with the following components has been tested:

- 1 supply manifold with flow regulators RCTMD-M
- 1 return manifold for thermo actuators RTEV-M;
- button operated sliding connectors type RPLPUTERRB20/M.


#### Testing modalities:

The circuit has been connected to a **hydraulic circuit**, made with a LOWARA E A 20 6/130 pump and 25 meters of 20x2 multilayer hoses.

The flow rate has been settled on the first flow regulator.

Opening progressively the flow regulators of the following ports, the number of ports granting the same flow rate has been established.

Picture n° 9  
**Flow rate on different ports**  
**- Testing modalities -**



## **Obtained results**

Setting the flow rate of the flow regulators at 3 l/min, n° 14 regulators grant the same flow rate.  
Setting the flow rate of the flow regulators at 4 l/min, n° 8 regulators grant the same flow rate.  
These results depend on the pump characteristics, which influence the circuit.



## TEST REPORT

PBRP1137e  
Rev.2  
Page 28 of 30

### **4.8 CONNECTING FORCE OF THE SLIDING QUICK CONNECTORS**

#### **Tested samples:**

1 button operated connector RPLPUTERRB17 has been tested.

#### **Testing modalities:**

The sample has been connected on the respective manifolds and PEX pipe, measuring the force applied for the connection, with a suitable a dinamometer.

Picture n° 10

#### **Connecting force of the button operated connector – Testing modalities –**





## TEST REPORT

PBRP1137e  
Rev.2  
Page 29 of 30

### Obtained results

On the basis of the obtained results, the following values have been fixed to be considered during installation:

Sliding quick connector	Connecting force to the manifold	Insertion force of the PEX pipe
Button operated connector RPLPUTERR	$\leq 11$ kg	$\leq 18$ kg



## TEST REPORT

PBRP1137e  
Rev.2  
Page 30 of 30

### 5. CONCLUSION

On the basis of the obtained results, the manifolds are suitable for the intended use.